


THIS DRAWING IS AN INDICATIVE LAYOUT DRAWING ONLY AND HAS BEEN PREPARED BY EOBA FOR THE CONFIDENTIAL USE OF THE CLIENT FOR WHOM THE DRAWING WAS UNDERTAKEN. EOBA ACCEPTS NO DUTY, RESPONSIBILITY (INCLUDING IN NEGLIGENCE) OR LIABILITY TO ANY PARTY OTHER THAN THE CLIENT ARISING OUT OF OR IN CONNECTION WITH THIS DRAWING. IN PARTICULAR, IN PROVIDING THIS DRAWING EOBA HAVE EXERCISED THE STANDARD OF SKILL AND CARE REQUIRED UNDER THE APPOINTMENT AND WILL HAVE NO DUTY, RESPONSIBILITY OR LIABILITY ARISING OUT OF OR IN CONNECTION WITH ANY EQUIPMENT, PRODUCTS OR DELIVERABLES SUPPLIED BY THE CLIENT OR

ANY THIRD PARTY IN ACCORDANCE WITH THE DRAWING ("DELIVERABLES") INCLUDING THE USE OF OR CONSEQUENCE OF SUCH DELIVERABLES. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE COMPLIANCE REPORT.



MEZZANINE

15.2200

TEA STATION

WORKSTRICE

12.2300

TEA STATION

WORKSTRICE

12.2300

TEA STATION

WORKSTRICE

12.2300

TEA STATION

WORKSTRICE


EXISTING FIRST FLOOR PLAN

SCALE 1:200


SECTION BB SCALE 1:50

EXISTING GROUND FLOOR

SCALE 1:200







C 16/12/19 EXIT DOOR REMOVED
B 12/12/19 ADDITIONAL INFORMATION
A ISSUED ----

FIRE SAFETY CERTIFICATE



## and Associates chartered fire engineers &

event safety consultants

51 CULLENSWOOD ROAD, THE TRIANGLE, RANELAGH, DUBLIN 6
PHONE: 01 4982178 FAX: 01 4982147
EMAIL: info@eoba.ie WEBSITE: www.eoba.ie

ORDNANCE SURVEY IRELAND DATA REPRODUCED UNDER
OSI LICENCE NUMBER No. AR 0104619
© ORDNANCE SURVEY IRELAND / GOVERNMENT OF IRELAND

CLIENT:

LEGEND:

FIRE DOORS

SITE BOUNDARY

DISABLED REFUGE AREA

EUROPEAN NATIONAL NOTES

FIRE RESISTANCE OF ELEMENTS OF STRUCTURE

TRAVEL DISTANCE

METHOD OF MEASUREMENT for means of escape purposes only

EXIT SIGNPOSTING

WIDTH OF A DOOR:

DOORS ARE OPEN.

THIS WIDTH MAY BE IGNORED.

INTO THIS WIDTH MAY BE IGNORED.

WIDTH OF A STAIRWAY:

AREA TO WHICH THIS APPLICATION RELATES

HATCHED AREA DOES NOT FORM PART OF THIS APPLICATION

30 MINUTES FIRE RESISTANT DOORSET WITH

INTUMESCENT STRIPS AND COLD SMOKE SEALS

TEGRITY INSULATION INFORMATION ON THE FIRE RESISTANT ELEMENTS OF STRUCTURE WITHIN THE BUILDING.

 REI 30
 30
 30
 30 minutes fire resistant wall / floor

 REI 60
 60
 60
 60 minutes fire resistant wall / floor

REI 60 60 60 60 60 GO LOADBEARING WALL / STRUCTURAL COLUMN TO ACHIEVE 60 MINUTE FIRE RESISTANCE

REI 60 60 60 60 60 60 MINUTES FIRE RESISTANT COMPARTMENT WALL / FLOOR

REI 60 60 60 60 EXISTING SEPARATING WALL OR TO BE UPGRADED TO 60 MINUTES FIRE RESISTANT COMPARTMENT WALL / FLOOR

THE WIDTH OF A DOORWAY IS THE CLEAR WIDTH WHEN THE DOOR OR

DOOR HARDWARE WHICH DOES NOT INTRUDE MORE THAN 100mm INTO

WIDTH OF A ESCAPE ROUTES: THE WIDTH OF AN ESCAPE ROUTE IS THE WIDTH AT 1500mm ABOVE FLOOR

LEVEL WHEN DEFINED BY WALLS OR ELSEWHERE THE MINIMUM WIDTH OF

HANDRAILS FIXED TO WALLS WHICH DO NOT INTRUDE MORE THAN 100mm

THE EMERGENCY FIRE EXIT SIGNAGE WILL BE IN ACCORDANCE WITH

IS THE CLEAR WIDTH BETWEEN WALLS OR BALUSTRADES.

STRINGS INTRUDING LESS THAN 30 mm MAY BE IGNORED.

HANDRAILS INTRUDING LESS THAN 100 mm MAY BE IGNORED.

PASSAGE AVAILABLE BETWEEN ANY FIXED OBSTRUCTIONS.

EXIT SIGNPOSTING WILL BE PROVIDED AT ALL FINAL EXITS AND STOREY EXITS AND SUPPLEMENTED BY DIRECTIONAL SIGNPOSTING WHERE THE ROUTE TO EXIT IS UNCLEAR. EXIT SIGNPOSTING SHOWN IN THE DRAWING ARE ONLY FOR REFERENCE PURPOSE.

REFER TO APPENDIX A OF THE REPORT FOR ADDITIONAL

EXTERNAL WALLS REQUIRED TO BE FIRE RESISTING FOR

50 MINUTES FIRE RESISTANT WALL / FLOOR

Martin Doran

Change of use
Buckley Hall - Dublin 01
Existing Plans, proposed plans & sections

 Dwg No: 18117-FS-02
 Scale:
 As shown @ A1

 DRAWN BY:
 JS
 DATE:
 12/12/19

 CHECKED BY:
 MS
 REV:
 C